

**VITARAG ASSOCIATES**  
**STRUCTURAL CONSULTANTS**  
**&**  
**RESEARCH CENTER**

34A/26 West, New Pachha Peth, Ashok Chowk, Solapur

Mob. No.-9552529235, 8767420940.

E-mail: vitragassociates3@gmail.com

**Outward No:** VAS-351-2022

**Date:** - 30/06/2022

**Structural Stability Certificate**

1. **Proposal** : R.C.C. framed structure building
2. **Name and Address of project** : Nagesh Karajagi Orchid School  
Sona shankar Dyanvikas Trust, Solapur.  
T. P. 4, Final Plot No.125/2, Sub Plot No.1/28, Juni Mill  
Compound, Murarji Peth, Solapur.
3. **Name and Address of Architect** : --
4. **Nature of use of building** : Institutional Building
5. **Number of floors of building** : Ground + 6 uppers Floors

The Quality of a Construction is as per our Design and Drawings. Hence the Structure is safe and stable. Reinforced Concrete Design and Detailing is based on Appropriate Indian Codal Provisions.

**References:**

**IS : 456-2000** (Plain And Reinforced Concrete Code For Practice)

**IS : 875 Part -1** (Code of Practice for Design loads-Dead Loads)

**IS : 875 Part-2** (Code of Practice for Design loads- Imposed loads)

**IS : 875 Part-3** (Code of Practice for Design loads- Wind loads)

**IS : 1893 Part-1-2016** (Criteria for earthquake resistant design of structures)

**IS : 13920-2016** (ductile detailing of reinforced concrete structures)

Thanking You,

Yours Faithfully,

*P.A.*

**VITARAG ASSOCIATES**

**(P. A. Sangave)**



S.M.C. LIC. NO. DDMCS/R/2022/APL/01262.



सोलापूर महानगरपालिका, सोलापूर  
**अग्निशमन व आणीबाणी सेवा**

रविवार पेठ, मुख्य अग्निशामक केंद्र, सोलापूर - ४१३००५. फोन : ०२१७-२७४०३६४/१०१

संदर्भ : जा.क्र. सा.आ.अ / अ.शा.व./ 478

दिनांक : 22/08/2022

प्रति,

सचिवा

सोनाशंकर ज्ञानविकास ट्रस्ट,  
नागेश करजगी ऑर्किड स्कूल,  
125/2 मरारजी पेठ, जुनी मिल कंपाऊंड,  
सोलापूर

विषय : अग्निशामक दल नुतनीकरण दाखला मिळणे बाबत...

संदर्भ : आपणाकडील दि. 03/08/2022 चे पत्र.

महोदय,

उपरोक्त संदर्भाकित पत्रातील विषयास अनुसरून आपण नागेश करजगी ऑर्किड स्कूल, 125/2 मरारजी पेठ, जुनी मिल कंपाऊंड, सोलापूर या स्कूल बिल्डींग चे अग्निशामक दलाचा नुतनीकरण दाखला (सन 2022-23) करीता आपण इकडील कार्यालयास विनंती अर्ज सादर केले आहे.

सबब सदर ठिकाणी भेट देवून तपासणी केले असता त्यामध्ये खालील प्रमाणे अग्निशमन सुविधा वाढविणे आवश्यक आहे

- 1) सदर ठिकाणी प्रत्येक मजल्यावर ABC टाईप 6 Kg चे 3 नग या प्रमाणे फायर एस्टींग्युशर बसविण्यात यावे.
- 2) फायर एस्टींग्युशर यांचे वेळच्यावेळी परिक्षण व रिफेल्डिंग करणे.
- 3) सदर ठिकाणी नियुक्त सुरक्षा रक्षक व कर्मचारी, रहिवासी यांना वरील यंत्रणा व उपकरणे (आग विझवण्याची) हाताळण्याचे प्रशिक्षण देणे.
- 4) सदर स्कूल बिल्डींग मध्ये 900 LPM चे 2 नग फायर पंप बसविण्यात यावे. (सेंट्रीफ्युगल पंप)
- 5) प्रत्येक मजल्यावर 2 नग फायर होस पाईप (15+15 Mtr.) होस बॉक्स सहित बसविण्यात यावे.
- 6) प्रत्येक मजल्यावर 20 मि. लांबीचे होजरील सिस्टीम बसविण्यात यावी.
- 7) अपात्कालीन सभयी बाहेर पडण्याचे दिशा दर्शक बोर्ड प्रत्येक मजल्यावर लावण्यात यावे.

अग्निशमन सल्लागार महाराष्ट्र शासन यांचे कडील नोंदणीकृत परवाना धारक फर्म कडून वरील नमूद अग्निशमन व्यवस्था करून घेण्याच्या अटीवर सदरचा दाखला देण्यात येत आहे.

मा. कळावे

दि.22/08/2022

प्र.मुख्य अग्निशमन अधिकारी

अग्निशामक दल,

सोलापूर महानगरपालिका, सोलापूर

Seal

Solapur Municipal Corporation, Solapur  
Indrabhavan, Punyashlok Appasaheb Warad street, Railway Lines, Solapur

O.W.No.Dh.K.V./Mu.S.A./39

Date 04/08/21

To,

Varsha Ravikiran Vibhute  
Sonashankar Dyanvikas Tust,  
Nagesh Karajagi Orchid School,  
125/2, Muraraji Peth, Solapur

Reference: Opinion of Divisional Officer no. 1 vide O.W. No. 89 Dt.  
12/07/2022.

**CERTIFICATE**

As per the referred letter Varsha Ravikiran Vibhute, 125/2, Muraraji Peth, Juni Mill Compound, Solapur has applied for grant of Health certificate for their Dyanvikas Tust, Nagesh Karajagi Orchid School bearing City Survey No. 125/2.

According to the above reference dt. 12/07/2022, after going to the site and inspecting it, it was seen that the bins were kept separately after sorting the waste at the said place. The toilet connection at said place is connected to the drainage line. Cleanliness was observed in the school premises. The concerned Health Inspector and Divisional Officer no. 1 has given feedback.

However, according to the said opinion, the said certificate is being given.

M.K. Dt. 25/07/2022

Sign/-

Chief Cleaning Superintendent  
Solid Waste Management Department

Seal





**MAHARASHTRA STATE PUBLIC HEALTH SERVICES**

District Health Laboratory, Solapur

Telephone No. 0217-2501296

**Microbiological Report of Water Sample**

To,	Varsha Ravikiran Vibhute Secretary, Sonashankar Dnyanvikas Trust, Solapur.			
Sender's Letter No. and Date	155	Date 13/06/2022		
Laboratory Reference No.	5			
Date of Sample	Date 13/06/2022			
Date of arrival of Sample	Date 13/06/2022			
Date of Commencement of examination	Date 13/06/2022			
Sr No.	Sample of Opinion	Findings of the Test		Other Feedback
		Per 100 ml in the sample		
		Coliforms	Thermotolerant Coliforms	
1	Sonashankar Dnyanvikas Trust, Nagesh Karajagi Orchid School, 125/2 Muraraji Peth, Old Mill Compound, Solapur	0	----	Potable

Feedback- The Non-potable water can be used for drinking only after appropriate chlorine treatment and microbial re-inspection to ensure that it is safe to drink.

Report 842/22

Date 17/06/2022

The said water sample is taken as a representative sample. This is assumed

